



BILL OF MATERIALS

ITEM NO.	QTY.	TWR PART NO.	DESCRIPTION
1	1	OL2	DOUBLE OBSTRUCTION LIGHT
2	2	116A21TS	116 WATT 120 VOLT LAMP
3	2	5012902	BREATHER
4	1	SS10012	WRAPLOCK
5	2	JB5	3/4" JUNCTION BOX
6	1	PIPDOP	4 oz. PIPE DOPE
7	5	A314	3/4" CONDUIT LOCKNUTS
8	2	EL3490	3/4" 90° SHORT ELBOW
9	1	N34T4	3/4" X 4" CONDUIT NIPPLE
10	1	OL2PIGTAIL	18" OL2 PIGTAIL
11	2	UNY205	3/4" UNION
12	1	AA0M	AA0-M ALARMED CONTROLLER

ITEM NUMBERS #13-#15 ARE NOT INCLUDED IN THE KIT BUT ARE REQUIRED FOR INSTALLATION.

13	-	CONDUIT34	3/4" CONDUIT (TWR HT. + 30'/9M)
14	-	14THHNWHT	#14 THHN WHT. WIRE (TWR HT.+40'/12M)
15	-	14THHNBK	#14 THHN BLK. WIRE (TWR HT.+40'/12M)

* = ITEM NOT SHOWN

NOTES:

- 1) CONDUIT SIZE BASED ON USING TYPE THHN WIRE.
- 2) USE RIGID GALVANIZED STEEL CONDUIT.
- 3) BREATHERS ALLOW FOR CIRCULATION OF AIR TO PREVENT CONDENSATION.

LK1A0M & LK1CA01M LIGHTING KIT W/ALARMED CONTROLLER (TOWERS 21'/6M TO 100'/31M)

TWR Lighting, Inc.

04/24/96 (D) REVISED B.O.M.	APP'D	ENGINEER	CHK'D BY
03/18/96 (C) UPDATED B.O.M.	DRAWN BY E.A.SALAZAR		SHEET SIZE B SHEET QTY. 1 OF 1
9/9/94 (B) REWORK KIT PARTS	DATE 1/5/93	SCALE N.T.S.	DRAWING NO. 258-01
2/25/94 (A) ADDED MATERIALS	DATE: LTR. REVISION		

NOTICE: This drawing is the property of TWR Lighting, Inc. All information contained herein that is not generally known shall be confidential except to the extent the information has been previously established. This drawing may not be reproduced, copied or used as the basis for manufacture or sale without written permission.